

MAP 50 D3 Par 121 3033473

Cullum, Roland

Calvary Methodist Church

Fee
 New 15.00
 Correct 5.00
Receipt Number

HARFORD COUNTY HEALTH DEPARTMENT

119 Hays Street • Bel Air, Maryland 21014
838-6000, Ext. 217 • 879-2000

Type of Request
 New System
 Correction/
Addition/
Replacement

ON-SITE SEWAGE DISPOSAL

APPLICATION:

Owner Calvary Methodist Church
Builder or General Contractor Roland M. Cullum 918 Tubert St. Bel Air
Septic System Installer _____
Phone No. 838-5521

Plumber Bonded Drainlayer Owner

Exact Location of Building Site 1371 Calvary Rd. Churchville Md.

Size of Lot _____ ft. X _____ ft. acreage 5 Existing Septic System Yes No

Building Use: 1. Residential No. of Bedrooms _____
 A. Individual B. Multifamily C. Mobile Home
2. Commercial (Give exact use) _____
3. Other (Give exact use) _____
Roland M. Cullum, Treas.

PERMIT - Office Use Only

Building Permit Number _____

1. Type of System: Septic Tank and Deep Trenches Septic Tank and Tile Field
 Septic Tank and Seepage Pit Other
2. Tank: OK'd tank A. Capacity 1500 Gallons B. Tank Material Concrete Metal Other
3. Disposal Requirements: Length 180 FT Width 2 FT Depth 8 FT
15' from bldg. The installer said this was necessary due to the location of the cemetery. There wouldn't be enough room for the drainfield otherwise.

Distances: Maintain a minimum of 75 feet between Disposal Area and any drilled well. Maintain a minimum of 100 feet between Disposal Area and any shallow well, spring or stream.

Percolation Test: Date 5-3-79 Results 2 min @ 10' 8 FT, 8 Dep Soil Type Wet Anytime
Time/E.S.S.A./Max Depth

Special Requirements or Conditions: Install in area of Perc Test.
Permit Number 1936-82
Date Issued 4/14/82
Date Completed No FINAL
Inspected By Per P.J.
6-15-84

Applicant must return both copies to the Harford County Health Department for issuance of permit. Expires one (1) year from date of issuance. All work must be inspected prior to covering. Call 24 hours prior to completion. Scale drawing on other side (For use by inspector only).

**Harford County
Department of Health**

119 HAYS STREET • P.O. BOX 191
BEL AIR, MARYLAND 21014

DEPUTY STATE
AND COUNTY HEALTH OFFICER

I. H. CANFIELD, M.D., M.P.H.

TELEPHONE 838-6000

R. N. Cullum RESULTS OF SOIL TESTING

TO : Calvary United Methodist Church
FROM : Division of Community Health Protection 918 Luke St.
Bellair, Md 21014
FILE : MISC. NAME: _____ SUBDIVISION _____

APPLICANT: _____ ADDRESS: _____ PHONE _____

OWNER: _____ ADDRESS: _____ PHONE _____

LOCATION: E/S Rt 136 @ 1000' N of James Run Rd.

TAX MAP: 50 PARCEL: 121 LIBER: _____ FOLIO: _____ SECTION: _____ LOT: _____

SIZE: D-3 ACRES: 5.4 SOIL MAP: 36 SOILS: Le, Ne, Sa, Av.

HOLE	DEPTH	SOIL DESCRIPTION	START	FINISH	DROP	TIME
<u>A</u>	<u>@</u>	<u>75 to left of church facing church from road.</u>				
	<u>10'</u>	<u>cover 1' clay 1-3' sap 3-10'</u>	<u>2:50</u>	<u>2:51</u>	<u>2:53</u>	<u>2" 2min.</u>
		<u>Capacity @125 @average @50/sunday.</u>				
		<u>70 x 40</u>				
						<u>Perc 2min.</u>

REMARKS: See plat for perc location - Septic in location perc A

TEST LOC.: See plat ESAA: 10ft² TRENCH DEPTH: 8' WELL LOC.: See plat

BACKHOE: D. Anderson PERSONS PRESENT: _____

SANITARIAN: F. Williams TIME: 2:30PM DATE: 5-3-79

Calvary United Methodist Ch.